

## भा.कृ.अनु.प. - केन्द्रीय रोपण फसल अनुसंधान संस्थान

प्रादेशिक केन्द्र, कृष्णपुरम (डाक), कायमकुलम, केरल 690 533, भारत ICAR - CENTRAL PLANTATION CROPS RESEARCH INSTITUTE REGIONAL STATION, KRISHNAPURAM (PO), KAYAMKULAM 690 533, KERALA, INDIA



(An ISO 9001:2008 Certified Institution)

Phone: PABX: 0479-2442104; 0479 – 2442160 Head: 0479-2442004 Fax: 0479-2445733 Email: headrskgm.cpcri@icar.gov.in, headcpcri@yahoo.co.in Website: http://www.cpcri.gov.in

No.F.1(23)XIIth Plan/2012-17 Dated 22-07-2016

To

Sub:- Quotation for the supply of 5 KVA UPS - reg.

Sirs,

Sealed quotations are invited for the supply of 5 KVA UPS with 6 hours back up with the following specifications to this Station.

S.No. Description	Onty.
5 KVA UPS :TECHNICAL SPECIFICATIONS  Should be 5 KVA UPS with double conversion online Should work with input voltage range of 160 to 220 V Should have truly sinusoidal waveform out put Should have zero delay changeovers Should be with output voltage 220-240 V and current monitoring Power outlet terminated in sockets with isolator protection LED indicators: Mains on, battery on charge, low battery imminent, lon inverter, load on auxillary supply etc. Electrical Protection: Input/output/under volt, overload, short circuit & battery low, surge protection, inbuilt overvoltage cutoff device etc. Isolation transformer between UPS output and Supply Mains Type of batteries: Sealed Maintenance Free (SMF) Warranty: Minimum 3 years with replacement guarantee (both for Ul & battery) Minimum — 12480 VAH	

The quotations should confirm to the following terms & conditions:-

- 1. The rates quoted should be valid for a minimum period of 90 days from the due date of receipt of quotation.
- 2. Complete description, specification of the item(s) quoted should be given.
- 3. Should indicate time required or effecting the supply/installation upon receipt of supply order.
- 4. Should indicate the rate of ST/CST/ED/VAT/Entry Tax etc. if charged extra.

- 5. Should specify whether the item quoted are under DGS&D rate contract. If so details of the rate contract should be furnished with the quotation.
- 6. Quotation should clearly indicate the point of supply such as Ex-works/FOR despatch Station/FOR destination.
- 7. BID SECURITY @ 3% of the quoted amount must be deposited by Demand Draft in favour of ICAR UNIT CPCRI (RS) Kayamkulam" on SBT Kayamkulam. Deposit at Call Receipt of the State bank of Travancore will also be accepted as earnest money provided the receipt obtained from the bank is attached with the quotation. Remittance of EMD in any other mode not acceptable.
- 8. TRANSIT INSURANCE: The purchaser will not pay separately for transit insurance. The supplier will be responsible for the delivery of the entire stores contracted, in good condition at destination.
- per each month or part thereof in respect of suppliers so delayed and delivered 10. Time required for effecting supply upon receipt of supply order should be indicated.

9. The buyer shall have the right to levy liquidated damage at a percentage not exceeding 5%

11. Guarantee offered for item should be indicated from the date of receipt and installation of item.

12. Payment will be made only after satisfactory receipt and completion of installation of the

- 13. Quotation received after the due date will not be entertained.
- 14. The item ordered should be supplied in a lot. Part supply will not be accepted.

to

item. No advance payment/part payment is admissible as per rules.

- 15. The rights to accept or reject the quotation rests with the Head, ICAR-CPCRI (RS) Kayamkulam.
- Successful tenderer shall have to furnish an unconditional performance security for an 16. of the order value immediately after confirmation of the acceptance of amount of 10% quotation for placing order. Performance security may be furnished in the form of an Account
- Payee Demand Draft, FD receipt or Bank Guarantee from any Nationalized Bank in an acceptable form. The performance security valid for a period of 60 days beyond the date of completion of all the contractual obligations. The performance security will be converted in to as security deposit during warranty/guarantee period and the supplier should extend the validity of performance guarantee period up to the last date of completion of the warranty/guarantee period of the equipment as per warranty/guarantee obligations.

successful

tender

Your sealed quotation superscribed as Quotation for supply of 5 KVA UPS due on 12-08-2016 may be sent to this office on or before 12-08-2016.

the

copy to website.

refunded

Security

security.

will

be

Yours faithfully.

of performance

on receipt